

Test Verification of Conformity

Verification Number: 220930018GZU-VOC002

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

Applicant Name & Address:	Shenzhen Growatt New Energy Co., Ltd. 4-13/F, Building A, Sino-German (Europe) Industrial Park, Hangcheng Ave, Bao'an District, Shenzhen, China
Product Description:	Lithium-ion battery system
Ratings & Principle Characteristics:	Nominal voltage: 400V Rated energy: 20000Wh Charge current: Max. 33A End of charge voltage: 550V (Cell 3.65V) Discharge current: Max. 33A End of discharge voltage: 380V (Cell 2.5V)
Models/Type References:	APX 20.0P-S0-US
Brand Names:	GROWATT
Specification<s>/Standards:	ANSI/CAN/UL 9540A:2019 (Fourth Edition) + UL CRD's (Unit level)
Verification Issuing Office Name & Address:	Intertek Testing Services Shenzhen Ltd. Zengcheng Branch C2-1, Heping Xu, Yongning Street, Zengcheng District, Guangzhou, China
Date of Tests:	03 Mar. 2023 – 07 Mar. 2023
Test Report Number(s):	220930018GZU-002



Signature

Name: Tommy Zhong

Position: Technical Manager

Date: 04 May 2023

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.